

PEACHTREE CITY FIRE-RESCUE

FOOD TRUCK REQUIREMENTS



- Mobile Food Preparation Vehicles will be required to have permits issued by the Peachtree City Fire Marshal's Office in order to operate in Peachtree City
- Prior to permitting, an inspection must be completed by the Fire Marshal's Office
- To schedule an inspection, call 770-631-2526
- Inspections and permits will be valid for 1 year.
- Inspections will be based off criteria set forth in the 2018 edition of the International Fire Code (IFC)
- Inspection items include
 - **2018 IFC 319.3** Cooking equipment that produces grease-laden vapors shall be provided with a kitchen exhaust hood in accordance with **2018 IFC Section 607** and this system must be cleaned and maintained in accordance with **2018 IFC 607.3**
 - **2018 IFC 607** Exhaust hoods must be designed and installed in accordance with UL 710
 - Hoods are not required for an electric cooking appliance where an approved testing agency provides documentation that the appliance effluent contains 5mg/m³ or less of grease when tested at an exhaust flow rate of 500 cfm in accordance with UL 710B
 - **2018 IFC 319.4.1** Cooking equipment shall be protected by automatic fire extinguishing systems in accordance with **2018 IFC 904.12** and this system must be tested and maintained in accordance with **2018 IFC 901.6**
 - **2018 IFC 904.12** The automatic fire extinguishing system must be listed and labeled in accordance with UL 300 and comply with NFPA 13
 - **2018 IFC 901.6** The automatic fire extinguishing systems must be tested and inspected every 6 months and have a valid inspection tag displayed
 - **2018 IFC 319.4.2** Portable Fire Extinguishers shall be provided in accordance with **2018 IFC 906.4**
 - **IFC 906.4** Mobile Food Preparation vehicle shall have an ABC fire extinguisher that has a valid annual inspection tag
 - **IFC 906.4** Units that require an automatic fire extinguishing system shall also have a Class K fire extinguisher with a valid annual inspection tag
 - **2018 IFC 319.5** Gas cooking appliances shall be secured in place and connected to fuel-supply piping with an appliance connector complying with ANSI Z21.69/CSA 6.16. The connector installation shall be configured in accordance with the manufacturer's installation instructions. Movement of appliances shall be limited by restraining devices installed in accordance with the connector and appliance manufacturers' instructions.
 - **2018 IFC 319.6** Cooking Oil storage containers within mobile food preparation vehicles shall have a maximum aggregate volume not more than 120 gallons and shall be stored in such a way as to not be toppled or damaged during transport.
 - **2018 IFC 319.8 and 319.9** LP and CNG systems shall be installed per this code and appropriate gas detection devices must be installed in the vehicle.